

Test Name: Nozzle Flow Rate Measurement

Test Instruction Code: ITE/LB.I-27

Test purpose: Measuring the outlet flow rate of the nozzle.

Applicability domain: All Nozzle Types.

Standard number: Imen Tiar Engineering Factory Standard.

Test method: After installing the monitor and nozzle system on the test apparatus, the flow rates at the specified pressures as stated by the requirements of the customer shall be measured via flow metre. The observed values shall be within the allowable limits specified by in customer's requirements.

نام آزمون: دبی سنجی نازل

کد دستورالعمل آزمون: ITE/LB.I-27

هدف از آزمون: سنجش میزان دبی خروجی از نازل و مطابقت آن با مقدار اعلام شده در الزام مشتری.

دامنه کاربرد: کلیه نازل ها

شماره استاندارد: استاندارد کارخانه ای شرکت مهندسی ایمن تیار
روش آزمون: پس از نصب سیستم مانیتور و نازل بر روی دستگاه آزمون، مقدار دبی را به ازای فشار اعلام شده در الزامات مشتری توسط جریان سنج، اندازه گیری می نمائیم. عدد مشاهده شده باید در محدوده مجاز اعلام شده در الزامات مشتری باشد.

